

## To Made the Sewerage System Functional

- 20.12.2021
586. **Dr. Krishan Lal Middha, M.L.A.:** Will the Chief Minister be pleased to state whether it is a fact that the sewerage system of Jind City is lying chocked; if so, the time by which it is likely to be made functional?

### **SHRI MANOHAR LAL, HON'BLE CHIEF MINISTER, HARYANA**

At present, Haryana Shahri Vikas Pradhikaran has developed six residential sectors namely Sector-6, 7, 8, 9, 10, 11 & 11 extensions at Jind City. The main sewer line from Bhagwan Parshuram Chowk to residence of Superintendent of Police, Jind and then along Gohana Road upto temporary disposal was laid in the year 1974. This sewer line gets partially choked occasionally and this line is de-silted immediately as and when required. However, due to heavy cost of maintenance and better functioning of the disposal of sewage effluent, this line needs to be replaced. Accordingly, an estimate costing Rs. 305.65 Lakh for providing new main sewer line along Safidon Bye Pass Road in Urban State, Jind has been administratively approved on 10.12.2021. Work against this estimate, is expected to be completed by 30.06.2022.

There is one Hydraulic-cum-Jetting Machine in the town for cleaning / removing chockage of sewerage system in the town. As and when any complaint is received regarding blockage / choking of sewerage system, the same is attended forthwith.